



MEMORANDUM

Date: Jan. 31, 2014

To: Jose Ribeiro, Senior Planner

From: Dion Walsh, JCSA Civil 1

Subject: SP-0007-2014 Busch Gardens Bus Stop Shelter

James City Service Authority has reviewed these plans for general compliance with the JCSA Standards and Specifications, Water Distribution and Sanitary Sewer Systems and has the following comments for the above project you forwarded on Jan. 30, 2014. Quality control and back checking of the plans and calculations for discrepancies, errors, omissions, and conflicts is the sole responsibility of the professional engineer and/or surveyor who has signed, sealed, and dated the plans and calculations. It is the responsibility of the engineer or surveyor to ensure the plans and calculations comply with all governing regulations, standards, and specifications. Before the JCSA can approve these plans for general compliance with the JCSA Standards and Specifications, the following comments must be addressed. We may have additional comments when a revised plan incorporating these comments is submitted.

General Comments:

1. Show and label the NNWW 30" water main that is located between the back of curb and the proposed bus shelter.
2. Per Dickie Hamrick with NNWW: The bus shelter building shall be no closer than 10' horizontally from the outside edge of the 30" water main. The location of the bus shelter may need to be moved farther away from the road to accommodate this requirement. Please verify. If you have any questions for Mr. Hamrick, he can be reached at 757-926-1070 or email dhamrick@nngov.com.

Please call me at 757-259-5457 if you have any questions or require any additional information.